

PLUMBING BOARD: NOTICE OF FINAL INTERPRETATION

On May 22, 2014, the Minnesota Plumbing Board issued a Final Interpretation, which is printed below, pursuant to Minnesota Statutes §§ 326B.435, subdivision 2(a)(4), and 326B.127, subdivision 5. This Request for Interpretation was heard by the Board at its May 20, 2014, special meeting.

Any person aggrieved by this Final Interpretation may appeal it by filing a petition for a writ of certiorari with the Minnesota Court of Appeals pursuant to Minn. Stat. § 14.63.

Questions may be directed to Wendy Willson Legge, phone: (651) 284-5126, *email*: wendy.w.legge@state.mn.us.

FINAL INTERPRETATION

Inquiry: PB0079

Subject: Exterior venting

Code Reference: Minnesota Plumbing Code, Minnesota Rules 4715.2330, 4715.2520, and 4715.2530

Submitted by: Mr. Harry Blonigen, BHH Property Management Inc. and H&C Enterprises LLC

Approved by: Minnesota Plumbing Board by John Parizek, Board Chair

Date received: April 28, 2014

Issue date: May 22, 2014

Background: On May 20, 2014, the Board considered en banc information regarding the application of the Plumbing Code as it relates to proposed venting from a residence as follows: having the vent pipe exit the home through a side wall and then proceed vertically up through the soffit portion of the roof. The vent pipe between the side wall and the soffit would be enclosed and insulated. The vent pipe would be three inches in diameter and the vent pipe would terminate not less than 12 inches above the roof.

Question: Would the proposed venting violate the Minnesota Plumbing Code, Minnesota Rules 4715.2330, 4715.2520, or 4715.2530.

Answer: The proposed venting would not violate Minnesota Rules 4715.2330, 4715.2520, or 4715.2530.

/s/John Parizek

John Parizek
Chair, Minnesota Plumbing Board